

Test Report No.: SHAIN23018961002 **Date:** Dec 12, 2023 Page 1 of 3

Client Name: Haining UV Decoration Material Co., Ltd.

Client Address: 2nd Floor, Building 1, No. 6, Lane 631, Lianhe Road, Haizhou Street, Haining City, Jiaxing

City, Zhejiang Province

Sample Name: Acoustic Panel

The above sample(s) and information were provided by the client.

SGS Job No.: SHIN2311001888CM03 IN-SH-CP-5627-23467

Sample Receiving Date: Nov 15, 2023

Testing Period: Nov 15, 2023 ~ Dec 10, 2023

Test Requested: Select test(s) as requested by the client.

Test Method(s): Please refer to next page(s).

Test Result(s): Please refer to next page(s).

Test Requirement	Conclusion
Formaldehyde Emission	Pass

Signed for and on behalf of SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd.

Jerry Jiang

Approved Signatory



Verification: check.sgsonline.com.cn



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.apxx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <a href="http://www.sgs.com/en/Terms-and-Conditions/Terms-and-Cond

3rdBuilding,No.889 Yishan Road Xuhui District,Shanghai China 200233

t E&E (86–21) 61402553 f E&E (86–21)64953679 t HL (86–21) 61402594 f HL (86–21)61156899

e sas china@sas com



Test Report No.: SHAIN23018961002 **Date:** Dec 12, 2023 Page 2 of 3

Test Result(s):

Test Part Description:

SN ID	Sample No.	SGS Sample ID	Description
SN1	001	SHA23-0189610-0001.C001	Black/yellow solid parts

Remarks:

- (1) 1 mg/kg = 1 ppm = 0.0001%
- (2) MDL = Method Detection Limit
- (3) ND = Not Detected (< MDL)
- (4) "-" = Not Regulated

Formaldehyde Emission

Test Method: With reference to EN 717-1:2004, analysis was performed by UV-Vis.

Test Item(s)	Limit	Unit(s)	MDL	001
Chamber No. CHEM-	-	g	-	1
Formadehyde Emission (In air)	0.124	mg/m³	0.080	ND
Conclusion				Pass

Notes:

(1) Reference Limit: EN13986:2004(E)

(2) Formaldehyde class E1: ≤0.124 mg/m³ air Formaldehyde class E2: >0.124 mg/m³ air

The maximum permissible limit is quoted from the client requirement.

Unless otherwise stated, the decision rule for conformity reporting is based on Binary Statement for Simple Acceptance Rule (w=0) stated in ILAC-G8:09/2019.



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <a href="https://www.sgs.com/en/Terms-and-Conditions/Terms-and-Con

3rdBuilding,No.889 Yishan Road Xuhui District,Shanghai China 200233 中国・上海・徐汇区宜山路889号3号楼 邮编: 200233

t HL (86-21) 61402594 f HL (86-21)61156899



Test Report No.: SHAIN23018961002 **Date:** Dec 12, 2023 Page 3 of 3

Sample Photo:



SGS authenticate the photo on original report only *** End of Report ***



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx, dor electronic format documents, subject to Terms and Conditions for Electronic Documents at <a href="http://www.sgs.com/en/Terms-and-Conditions/Terms-and-Conditio

3rdBuilding,No.889 Yishan Road Xuhui District,Shanghai China 200233 中国・上海・徐汇区宜山路889号3号楼 邮编: 200233 t E&E (86-21) 61402553 f E&E (86-21)64953679 www.sgsgroup.com.cn t HL (86-21) 61402594 f HL (86-21) 61156899